



Qenos Media Release – 1st December 2016

At approximately 2pm today, electricity supply to the Qenos Botany site was interrupted.

As a result, the Qenos flare system was operated as part of the safe shutdown of the Qenos Botany plants. Simultaneous loss of steam resulted in the smoke associated with this flaring.

EPA, Fire & Rescue NSW, NSW Police and local schools have been notified.

The plant has been safely shutdown and elevated flaring has ceased.

Further information about Qenos flare operation can be found at:

<http://www.qenos.com/internet/home.nsf/web/SGOH-98B974>

For further enquires call the Qenos Environmental Advisor on 0409 558 127